



Addendum No. 1

City of Bushnell

WATER MAIN INSTALLATION

(MATERIAL ONLY)

To: All Plan Holders for the above referenced project

From: City of Bushnell, Mary Carson (mcarson@cityofbushnellfl.com or 352-793-2591)

Date: April 28, 2021

RE: Addendum No. 1 – Material Correction – Water Main Installation (Material Only)

Addendum No. 1:

The size of Item No. 6 has been changed on the 10" water main material list. The correct item should read as **10" bell restraints**. Please acknowledge the revised material list that has been provided.

Acknowledge Receipt of Addendum No. 1:

Bidder's Signature

Date

ITB 2021-420-01

PROJECT: WATER MAIN INSTALLATION (MATERIAL ONLY)

SECTION 2 -MATERIAL LIST

10" Water Main Material

ITEM NO.	DESCRIPTION	QTY	PRICE/ITEM	TOTAL
1.	12"x 10" tapping saddle (Stainless steel)	1		
2.	10" Tapping valve	1		
3.	10" flange gasket and bolt kit	2		
4.	10"x 6" MJ Tee's	2		
5.	10" MJ Bolt and gasket kit	5		
6.	10" Bell restraints	8		
7.	6" MJ bolt and gasket kit	8		
8.	6" MJ square nut gate valves	2		
9.	10" Mega lugs for PVC C-900	5		
10.	10" MJ bolt and gasket kits	5		
11.	10"x 2" Tapping saddles For PVC C-900	2		
12.	14-gauge solid strand insulated wire	1500'		
13.	PVC C-900 DR18 Water main 10"	1180'		
14.	10"x 2" MJ cap	1		
15.	1" MIPT x PE corp stop	2		
16.	1"PE x 3/4" curb stop	2		
17.	2" square nut gate valve threaded	1		
18.	Standard Fire hydrant assembly 6" inlet (American or Mueller)	1		
19.	PVC C-900 DR-18 (6" water main)	20'		
			TOTAL:	